




Technical drawing of a mechanical part, labeled 7. The part is a horizontal plate with a central semi-circular feature. Dimensions are given in mm: total width 50, total height 24 (12+12), central semi-circular feature with radius R2.5, and a central slot with width 10 and depth 10. The drawing includes a section line and a detail view of the semi-circular feature.

Dimensions: $\phi 10 \text{ mm}$, $L = 92$, $(St 35V)$, $ost 3$.

Figure 7

BETON B 20 STAL- 34GS, StOS, St3SY.
MROZODPORNY
150 CYKLI
WODOSZCZELNY $W \gg 6$
OBJĘTOŚĆ BETONU $V = 0,40 \text{ m}^3$
MASA PŁYTY $G = 1029 \text{ kg}$

ZESTAWIENIE STALI							
Nr pręta	φ mm	Długość pręta cm	Ilość szt	Razem m			
				34 GS		St03	St3S4
				φ 12	φ 10	φ 6	φ 10
1	12	134	4	5,4			
1A	12	165	4	6,6			
1B	12	126	4	5,1			
1C	12	192	4	7,7			
2	10	LsR 52	58		30,2		
2A	10	LsR 60	14		8,4		
3	6	62	11			6,8	
4	6	40	8			3,2	
5	10	676	2		13,6		
6	12	204	6	12,3			
7	10	92	3				2,80
Razem m				37,1	52,2	10,0	2,8
Ciężar jednostkowy kg/m				0,888	0,617	0,222	0,617
Ciężar w/g φ kg				32,9	32,2	2,20	1,73
Ciężar w/g gat. stali				65,11		2,20	1,73
Masa całkowita				69,0 kg			

**PŁYTA POKRYWOWA
KOMORY PRZEPOMPOWNI
"ANTONIEWO 1"
Konstrukcja
Skala 1:10**

Przedsięwzięcie:		Sieć kanalizacji sanitarnej z przyłączami dla wsi Antoniewo gm. Golub-Dobrzyń			
Obiekt:		Kanalizacja sanitarna			
Branża:		sanitarna			
Inwestor:		Lokalizacja obiektu: Antoniewo; gm. Golub-Dobrzyń			
		Gmina Golub-Dobrzyń; Plac Tysiąclecia 25; 87-400 Golub-Dobrzyń			
Autoryzacja projektu:	Firma:	PRZEDSIĘBIORSTWO GOSPODARKI WODNO-ŚCIEKOWEJ "BIOBOX" Wiesław Mikołajczuk, ul.Polna 101; 87-100 Toruń			
	Funkcja:	Imię i nazwisko	Nr uprawnień	Specjalność	Podpis
	Projektant:	mgr inż. Wiesław Mikołajczuk	UAN-N-V/60/TO/84	Instal.- Inż.	
	Sprawdzający:	_____	_____	_____	
Kod rysunku:	Rodzaj projektu:	Data opracowania:	Skala:	Nr rys.:	
	PROJEKT WYKONAWCZY	lipiec 2012 r.	1:10	11	